

Informations lignes

Poste A	Poste B	courant maximum admissible	Résistance	Réactance	demi susceptance (10 ⁻⁶)
AUBANGE	XNODE1	1290	0,295	2,080	9,670
XNODE1	BELVAL	1290	0,580	4,082	18,981
BELVAL	TWINERG	1290	0,096	0,486	3,210
TWINERG	SCHIFFLANGE	1290	0,250	1,258	8,316
SCHIFFLANGE	BERTRANGE	1290	0,604	3,040	20,095
SCHIFFLANGE	BERTRANGE	1290	0,604	3,040	20,095
BERTRANGE	HEISDORF	709	0,645	3,247	21,461
BERTRANGE	HEISDORF	709	0,645	3,247	21,461
HEISDORF	ROOST	1290	0,779	3,990	25,514
HEISDORF	ROOST	1290	0,779	3,990	25,514
ROOST	FLEBOUR	1290	1,022	5,144	33,999
ROOST	XNODE2	1290	0,506	2,550	16,853
XNODE2	BAULER	1290	0,084	0,449	2,966
FLEBOUR	XNODE3	1290	0,506	2,547	16,835
XNODE3	BAULER	1290	0,084	0,449	2,966
HEISDORF	XNODE4	1290	1,676	8,584	54,884
XNODE4	QUINT	1290	1,247	6,278	41,495
HEISDORF	XNODE5	1290	1,676	8,584	54,884
XNODE5	TRIER	1290	0,632	3,183	21,037