

Informations lignes

Poste A	Poste B	ligne	courant maximum admissible [A]	Résistance [Ω]	Réactance [Ω]	Susceptance [μS]
Heisdorf	Quint	Heisdorf Quint Nord	1290	2.924	14.604	126.543
Blooren	Trier	Blooren Trier Süd	1290	2.737	14.143	402.124
Flebour	Bauler	Flebour Bauler Nord	2400	0.386	2.572	32.987
Flebour	Bauler	Flebour Bauler Süd	2400	0.298	1.498	12.893
Schiffflange	Aubange	Schiffflange PST-Schiffflange	982	0.003	0.050	0.192
Roost	Flebour	Roost - Flebour Ost	1290	1.022	5.144	44.274
Roost	Bissen	Roost - Bissen - Flebour	1290	0.390	2.598	33.144
Bissen	Flebour	Roost - Bissen - Flebour	1290	0.390	2.598	33.144
Heisdorf	Blooren	Heisdorf - Blooren	1290	0.676	3.611	261.695
Heisdorf	Roost	Heisdorf - Roost Ost	1290	0.779	3.923	33.615
Heisdorf	Roost	Heisdorf - Roost West	1290	0.779	3.963	33.615
Heisdorf	Bertrange	Heisdorf - Bertrange Ost	1290	0.645	3.280	27.960
Heisdorf	Bertrange	Heisdorf - Bertrange West	1290	0.645	3.280	27.960
Schiffflange	Berchem	Schiffflange - Berchem	1290	1.012	3.927	248.264
Schiffflange	Oxylux	Schiffflange - Sotel - Oxylux	1290	0.282	1.660	179.385
Schiffflange	Oxylux	Schiffflange - Oxylux	1290	0.376	2.164	204.204
Bertrange	Schiffflange	Bertrange - Schiffflange Ost	1290	0.604	3.072	26.075
Bertrange	Schiffflange	Bertrange - Schiffflange West	1290	0.604	3.072	26.075
Blooren	Berchem	Blooren - Berchem	1290	0.360	1.986	222.739
Blooren	Schiffflange	Blooren - Schiffflange	1290	1.156	6.037	256.982